

CERTIFICATE OF COMPLIANCE

Certificate Number 20160525-R26041
Report Reference R26041-20160518
Issue Date 2016-MAY-25

Issued to: PCJ INDUSTRIES CO LTD
199/24-25 Vibhavadeerangsit Rd
Samsennai
Payathai Bangkok 10400 THAILAND

**This is to certify that
representative samples of**

Dampers for Fire Barrier and Smoke Applications
Fire Damper, Model FDC

These dampers are of the curtain type rated up to and
including 3 hours.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 555, Fire Dampers.
CAN/ULC S112, Standard Method of Test of Fire Damper
Assemblies.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





EMME.R26041 Dampers for Fire Barrier and Smoke Applications

[Page Bottom](#)

Dampers for Fire Barrier and Smoke Applications

[See General Information for Dampers for Fire Barrier and Smoke Applications](#)**PCJ INDUSTRIES CO LTD**

R26041

199/24-25 Vibhavadeerangsit Rd
Samsennai
Payathai, Bangkok 10400 THAILAND

Fire Dampers for Use in Static Systems

Model	Hr Class	Damper Mounting Position	Single Section Damper Size, in.		Multiple Section Damper Size, in.	
			W	H	W	H
FDC	3	V	48	48	96	96



Trademark and/or Tradename:

[Last Updated](#) on 2016-05-31[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".